

FIRE SAFETY CERTIFICATE

No.377/RFO/FPW/GVMC/2022

Dated: 06-02-2024

Certified that the **S F S SCHOOL (CBSE BLOCK)**, building at **D.No.50-1-25, Seethammadhara, Visakhapatnam, Andhra Pradesh 530013** comprised of **02 Blocks / Ground + 02 upper floors** owned/occupied by **S F S S C H O O L (C B S E B L O C K)**, have complied with the fire prevention and fire safety requirements in accordance with the rule of A.P.State Fire Service Rules, and verified by the officers concerned of Fire Service on **14-12-2022** in presence of P.Vijay Kumar, S F S SCHOOL (CBSE BLOCK) building at D.No.50-1-25, Seethammadhara, Visakhapatnam and that the building / premises is fit for occupancy up to classes X (X/XII) With effect from **29-01-2023** for a period of **FIVE** years in accordance with rule and subject to compliance of specific conditions as appended.

1) Particulars of The building:

a)	Address of the Premises	S F S SCHOOL (CBSE BLOCK), D.No.50-1-25, Seethammadhara, Visakhapatnam, Andhra Pradesh 530013
b)	Total Plot Area	30,718.00 Sq. Mtrs.
c)	Height of the Building	09.00 Mtrs.
d)	No of blocks/ floors	02 Blocks / Ground + 02 Upper Floors
e)	Type of occupancy	Educational (School)

2) The floor wise details.

Sl. No.	Floor	Area in Sq. Meters.		Type of Occupancy
		SSC Block	Primary Block	
1.	Ground	1531.21	599.25	Educational (School)
2.	First	791.21	599.25	Educational (School)
3.	Second	219.35	599.25	Educational (School)
	Total	2541.77	1797.75	4339.52

3) Means Escape:

- The Management provided Four Internal Staircase with width of 1.50 Mtrs. for each Block from Ground floor to Terrace which is sufficient for occupant load.

4) The Minimum Fire Safety Installations required & provided by the Builder.


Sl. No	Fire Safety Measures	Required	Provided	Deficit
1.	Fire Extinguishers as per IS 2190	43 Nos.	43 Nos.	Nil
2.	Hose Reel	06 Nos.	06 Nos.	Nil
3.	Manual Call Points	06 Nos.	06 Nos.	Nil
4.	Terrace Tank	20,000 Ltrs.	20,000 Ltrs.	Nil
5.	Booster Pump	02 Nos. of 450 LPM.	02 Nos. of 450 LPM.	Nil
6.	Plunger Pump with 02 HP Motor	02 Nos. in each block	02 Nos. in each block	Nil

Contd.p.2

:: 2 ::

Issued on **29-01-2023** (date of issue) at Visakhapatnam by Regional Fire Officer, Fire Prevention Wing, Greater Visakhapatnam Municipal Corporation, Visakhapatnam.

Signature with Seal:


Regional Fire Officer
Fire Prevention Wing
Greater Visakhapatnam Municipal Corporation
Visakhapatnam

Name

: Y.HANUMANTHA RAO

Designation

: Regional Fire Officer

Name & Address of Department / Office:

Fire Prevention Wing, 4th floor, GVMC Zone-IV
office, Beside Venkateswara Theatre,
Suryabagh, Visakhapatnam-530020.

To
S F S SCHOOL (CBSE BLOCK),
D.No.50-1-25, Seethammadhara,
Visakhapatnam, Andhra Pradesh 530013

(Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Services stand cancelled and annulled due to non-maintain Fire Safety Measures at all times in good working Condition as seen during the inspection.

(Y.HANUMANTHA RAO, Regional Fire Officer)